

Submission to Planning Authority Notice

Application details

Council Planning Permit No. PDPSAMEND-2022/030778
Council notice date 9/09/2022
TasWater Reference No. TWDA 2022/01487-CCC
Date of response 22/05/2026
TasWater Contact Elio Ross
Phone No. 0467 874 330

Response issued to

Council name CLARENCE CITY COUNCIL
Contact details cityplanning@ccc.tas.gov.au
Development details
Address 22 GOODWINS RD, CLARENDON VALE
Property ID (PID) 2166880
Description of development Combined - Planning Scheme Amendment - rezone to general residential and open space + 79 lot Subdivision.

Schedule of drawings/documents

Prepared by	Drawing/document No.	Revision No.	Issue date
Rodgerson & Birch	Project: STAGC01 1440-04, Sheets 1 to 3	C	08/05/2026
Hutchings Spurr	Project: 24140, Sheets: 00, 03, 04, 05, 06, 07, 08, 20, 21, 22, 23	--	--
		C	01/05/2026
		B	29/04/2026

Response to Rezone Referral

Pursuant to the *Water and Sewerage Industry Act* 2008 (TAS) Section 56S(2) TasWater makes the following submission(s):

TasWater does not object to the draft amendment to the planning scheme and has no formal comments for the Tasmanian Planning Commission in relation to this matter and does not require to be notified of nor attend any subsequent hearings.

Conditions

Pursuant to the *Water and Sewerage Industry Act 2008 (TAS)* Section 56P(1) TasWater imposes the following conditions on the permit for this application:

CONNECTIONS, METERING & BACKFLOW

1. A suitably sized water supply with metered connection and sewerage connection to each lot of the development must be designed and constructed to TasWater's satisfaction and be in accordance with any other conditions in this permit.
2. Any removal/supply and installation of water meters and/or the removal of redundant and/or installation of new and modified property service connections must be carried out by TasWater at the developer's cost.
3. Prior to commencing construction of the subdivision, any water connection utilised for construction must have a backflow prevention device and water meter installed, to the satisfaction of TasWater.

ASSET CREATION & INFRASTRUCTURE WORKS

4. Prior to applying for Engineering Design Approval, the developer must physically locate all existing infrastructure to provide sufficient information for accurate design and physical works to be undertaken.
5. Plans submitted with the application for Engineering Design Approval must, to the satisfaction of TasWater show, all existing, redundant and/or proposed property services and mains.
6. Prior to applying for a Permit to Construct to construct new infrastructure, the developer must obtain from TasWater Engineering Design Approval for new TasWater infrastructure. The application for Engineering Design Approval must include engineering design plans prepared by a suitably qualified person showing the hydraulic servicing requirements for water and sewerage to TasWater's satisfaction.
 - a. A hydraulic water model of the proposed subdivision must be prepared for the ultimate development scenario in accordance with TasWater's Supplement to the Water Supply Code of Australia WSA O3 – 2011-3.1 MRWA Edition V2.0. The model may use any recognised software but must be exportable to EPANET.

The model, report and assumptions must be submitted to TasWater, demonstrating appropriate boundary conditions (including all relevant pressure zones) have been obtained, prior to approval of engineering design.

The engineering design must be consistent with the approved model, and any changes to layout, demand, staging or infrastructure that depart from the model must be supported by an updated model demonstrating continued compliance with TasWater's requirements.
7. Prior to works commencing, a Permit to Construct must be applied for and issued by TasWater. All infrastructure works must be inspected by TasWater and be to TasWater's satisfaction.
8. Prior to undertaking any works related to water and sewerage, physical markers must be in place that clearly identify where water and/or sewer connections are to be made in accordance with any approved plan to TasWater's satisfaction.

9. In addition to any other conditions in this permit, all works must be constructed under the supervision of a suitably qualified person in accordance with TasWater's requirements.
10. Prior to the issue of a Consent to Register a Legal Document all additions, extensions, alterations or upgrades to TasWater's water and sewerage infrastructure required to service the development, are to be completed generally as shown on, and in accordance with, the plans listed in the schedule of drawings and are to be constructed at the expense of the developer to the satisfaction of TasWater, with live connections performed by TasWater.
11. After testing to TasWater's requirements of newly created works, the developer must apply to TasWater for connection of these works to existing TasWater infrastructure, at the developer's cost.
12. At practical completion of the water and sewerage works and prior to TasWater issuing a Consent to a Register Legal Document the developer must obtain a Certificate of Practical Completion from TasWater for the works that will be transferred to TasWater. To obtain a Certificate of Practical Completion:
 - a. Written confirmation from the supervising suitably qualified person certifying that the works have been constructed in accordance with the TasWater approved plans and specifications and that the appropriate level of workmanship has been achieved.
 - b. A request for a joint on-site inspection with TasWater's authorised representative must be made.
 - c. Security for the twelve (12) month defects liability period to the value of 10% of the works must be lodged with TasWater. This security must be in the form of a bank guarantee.
 - d. Work As Constructed drawings and documentation must be prepared by a suitably qualified person to TasWater's satisfaction and forwarded to TasWater.

Upon TasWater issuing a Certificate of Practical Completion, the newly constructed infrastructure is deemed to have transferred to TasWater.

13. After the Certificate of Practical Completion has been issued, a 12-month defects liability period applies to this infrastructure. During this period all defects must be rectified at the developer's cost and to the satisfaction of TasWater. A further 12-month defects liability period may be applied to defects after rectification. TasWater may, at its discretion, undertake rectification of any defects at the developer's cost. Upon completion of the defect's liability period, the developer must request TasWater to issue a "Certificate of Final Acceptance". TasWater will release any security held for the defect's liability period.
14. The developer must take all precautions to protect existing TasWater infrastructure. Any damage caused to existing TasWater infrastructure during the construction period must be promptly reported to TasWater and repaired by TasWater at the developer's cost.
15. Ground levels over the TasWater assets and/or easements must not be altered without the written approval of TasWater.
16. A construction management plan must be submitted with the application for TasWater Engineering Design Approval. The construction management plan must detail how the new TasWater infrastructure will be constructed while maintaining current levels of services provided by TasWater to the community. The construction plan must also include a risk assessment and contingency plans covering major risks to TasWater during any works.

The construction plan must be to the satisfaction of TasWater prior to TasWater's Engineering Design Approval being issued.

FINAL PLANS, EASEMENTS & ENDORSEMENTS

17. Prior to the Sealing of the Final Plan of Survey, a Consent to Register a Legal Document must be obtained from TasWater as evidence of compliance with these conditions when application for sealing is made.
Advice: Council will refer the Final Plan of Survey to TasWater requesting Consent to Register a Legal Document be issued directly to them on behalf of the applicant.
18. Pipeline easements to TasWater's satisfaction, must be created over any existing or proposed TasWater infrastructure and be in accordance with TasWater's standard pipeline easement conditions and requirements.
19. Prior to the issue of a TasWater Consent to Register a Legal Document, the applicant must submit a .dwg file, prepared by a suitably qualified person to TasWater's satisfaction, showing:
 - a. the exact location of the existing TasWater infrastructure,
 - b. the easement protecting that infrastructure.

The developer must locate the existing TasWater infrastructure and clearly show it on the .dwg file. Existing TasWater infrastructure may be located by a surveyor and/or a private contractor engaged at the developers cost.

DEVELOPER CHARGES

20. Prior to TasWater issuing a Consent to Register a Legal Document the applicant or landowner as the case may be, must pay a developer charge totalling \$270,578.00 to TasWater for water and sewerage infrastructure for 77 additional Equivalent Tenements, indexed by the Consumer Price Index All groups (Hobart) from the date of this Submission to Planning Authority Notice until the date it is paid to TasWater.
21. In the event Council approves a staging plan, prior to TasWater issuing a Consent to Register a Legal Document for each stage, the developer must pay the developer charges commensurate with the number of Equivalent Tenements in each stage, as approved by Council.

DEVELOPMENT ASSESSMENT FEES

22. The applicant or landowner as the case may be, must pay a development assessment fee of \$1,353.71 and a Consent to Register a Legal Document fee of \$265.98 to TasWater, as approved by the Economic Regulator and the fees will be indexed, until the date paid to TasWater.

The payment is required within 30 days of the issue of an invoice by TasWater.

In the event Council approves a staging plan, a Consent to Register a Legal Document fee for each stage, must be paid commensurate with the number of Equivalent Tenements in each stage, as approved by Council.

Advice

General

For information on TasWater development standards, please visit

<https://www.taswater.com.au/building-and-development/technical-standards>

For application forms please visit

<https://www.taswater.com.au/building-and-development/application-information/application-for-development-services-form>

Important Notice Regarding Plumbing Plans and Associated Costs

The SPAN includes references to documents submitted as part of the application. These plans are acceptable for planning purposes only and are subject to further detailed assessment and review during the next stage of the development proposal.

TasWater's assessment staff will ensure that the design contains sufficient detail to assess compliance with relevant codes and regulations. Additionally, the plans must be clear enough for a TasWater contractor to carry out any water or sewerage-related work.

Depending on the nature of the project, your application may require Building and/or Plumbing permits or could be exempt from these requirements. Regardless, TasWater's assessment process and associated time are recoverable through an assessment fee.

Please be aware that your consultant may need to make revisions to their documentation to ensure the details are fit for construction. Any costs associated with updating these plans should be discussed directly with your consultant.

Developer Charges

For information on Developer Charges please visit the following webpage –

<https://www.taswater.com.au/building-and-development/developer-charges>

Service Locations

Please note that the developer is responsible for arranging to locate the existing TasWater infrastructure and clearly showing it on the drawings. Existing TasWater infrastructure may be located by a surveyor and/or a private contractor engaged at the developer's cost to locate the infrastructure.

- a. A permit is required to work within TasWater's easements or in the vicinity of its infrastructure. Further information can be obtained from TasWater.
- b. TasWater has listed a number of service providers who can provide asset detection and location services should you require it. Visit <https://www.taswater.com.au/building-and-development/service-locations> for a list of companies.
- c. Sewer drainage plans or Inspection Openings (IO) for residential properties are available from your local council.

Declaration

The drawings/documents and conditions stated above constitute TasWater's Submission to Planning Authority Notice.