



Our Ref: TWSI 2021/00290-GCC
Enquiries: Al Cole, Senior Assessment Officer
Direct Phone: 0439 605 108
Email: development@taswater.com.au

10 March 2022

Ann Cunningham

Chairperson
Development Assessment Panel
Tasmanian Planning Commission
tpc@planning.tas.gov.au

Dear Ms Cunningham

BRIDGEWATER BRIDGE MAJOR PROJECT – RESPONSE TO PROPONENT COMMENTS AND PROPOSED AMENDMENTS

TasWater provides the following comments to the Proponents representation, found on Pages 39-45, covering Conditions 43-60.

For Condition 43: TasWater is willing to reach an agreement with the proponent regarding cost contribution and design details. The detail around 3 x 500mm mains vs 3 x 300mm mains reflects the reality that TasWater would like mains with an internal diameter of 300mm, which translates to an outside diameter of 500mm when pipe thickness associated fittings are considered.

For Conditions 44-60, TasWater understands that the required works on our infrastructure will be undertaken by the proponent's contractor(s) and therefore we require these conditions to remain. We are happy to modify references to "developer" and "public tender process" as requested. Our initial advice was provided in advance of a chosen design and we will undertake to provide our final advice with specific reference to the final design.

TasWater strongly supports the Major Project and looks forward to a positive working relationship.

Yours sincerely,

Al Cole
Senior Assessment Officer

Tasmanian Water & Sewerage Corporation Pty Ltd
GPO Box 1393 Hobart Tas 7001
Email: enquiries@taswater.com.au
Tel: 13 6992

ABN: 47 162 220 653